



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Jun 10, 2022

**Inspection Result:** PARTIAL PASS

**Permit Number:** TB-21-934

**Issuance Date:** Sep 17, 2021

**Property Address:** 50310 MOON HILL DR, ROUTT, CO 80487;

**Applicant:** Nathan NicholasNathan Nicholas

**Contractor:** Mr. Gumpox Industries P O Box 773434 Steamboat Springs, Co 80477  
(970) 819-6740

**To construct:** 1,797 square foot single family home with detached garage.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Roof structural framing has been done to approved plans with 8" foam and sleepers on top with correctly timberlok fasteners to large rafters. Approved to finish roof.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347