



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Oct 07, 2021

**Inspection Result:**

**PASSED**

**Permit Number:** TB-21-934

**Issuance Date:** Sep 17, 2021

**Property Address:** 50310 MOON HILL DR, ROUTT, CO 80487;

**Contractor:** Mr. Gumpox Industries P O Box 773434 Steamboat Springs, Co 80477 (970) 819-6740

**To construct:** Work Description: 1,797 square foot single family home with detached garage.  
The estimated total cost of the home and garage is \$600,000.

Estimated total cost, minus the exempted items below is \$509,000.

Foundation Only issued 9.8.2021

FULL PERMIT ISSUED 9.17.21. MMF

On this day we have inspected your construction for **Foundation Drain Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Perforated drain pipe installed and bedded correctly for entire foundation to sump pit at SE corner. Correct gravel and fabric cover installed. Approved to backfill.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347

