



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Jul 22, 2022

**Inspection Result:** PARTIAL PASS

**Permit Number:** TB-21-922

**Issuance Date:** Aug 25, 2021

**Property Address:** 26355 HIDDEN MESA DR, ROUTT, CO 80467;

**Applicant:** YAMPA VALLEY ENGINEERING

**Contractor:** SPITELLIE CONSTRUCTION P.O. BOX 881971 STEAMBOAT SPGS, CO  
80488 (970) 846-2327

**To construct:** Work Description: To add a two story great room  
. net cost is \$150,000  
Total valuation \$200,000

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Rough framing, per plan and addendum. Steel post and beam connections made. Headers and trimmers to size. Rafters clipped and hangered. Load points followed with blocking. OK to insulate

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371