



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Aug 02, 2022

Inspection Result: PARTIAL PASS

Permit Number: PRFN220816

Issuance Date: Jun 29, 2022

Property Address: 23375 COUNTY ROAD 14, ROUTT, CO 80467;

Applicant: Hornbrook Builders

Contractor: Hornbrook Builders 617 Mountain Vista Circle Steamboat Springs, CO
80487 (970) 846-4725

To construct: New entry gate

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Entry gate piers, 8 verticals with 12"oc #3 hoops with three at the top. 4x4 HSS with weldments embed inserted per plan

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371