



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Aug 03, 2022

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRAB220721

**Issuance Date:** Jun 29, 2022

**Property Address:** 30857 COUNTY ROAD 53, ROUTT, CO 81639;

**Applicant:** Michael C Charchalis

**Contractor:** Four Rivers Construction LLC 175 Clay Avenue Craig, CO 81625 (970) 629-2839

**To construct:** New riding arena. This is an entirely open structure inside with no internal walls, no plumbing, and a dirt floor.

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Southern half of foundation has been formed correctly over drilled caisson piers. All rebar and anchor bolts are sized and spaced correctly. Approved to pour.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347