

Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Aug 04, 2022 Inspection Result: NOT READY

Permit Number: PRAB220721 Issuance Date: Jun 29, 2022

Property Address: 30857 COUNTY ROAD 53, ROUTT, CO 81639;

Applicant: Michael C Charchalis

Contractor: Four Rivers Construction LLC 175 Clay Avenue Craig, CO 81625 (970) 629-

2839

To construct: New riding arena. This is an entirely open structure inside with no internal

walls, no plumbing, and a dirt floor.

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments:

Corrections:

Sincerely,

Silas Ebbert Inspector sebbert@co.routt.co.us (970) 870-5347