



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 01, 2022

Inspection Result: PASSED

Permit Number: PRGS221224

Issuance Date: Aug 31, 2022

Property Address: 50310 MOON HILL DR, ROUTT, CO 80487;

Applicant: SCHRADER PROPANE LLC

Contractor: SCHRADER PROPANE LLC P.O. BOX 775450 STEAMBOAT SPGS, CO
80477 (970) 819-7363

To construct: underground, exterior gas line installation

On this day we have inspected your construction for **Gas Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: New exterior gas line has been installed and bedded correctly. Pressure test good for 15 minutes. Approved to backfill.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347