



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 06, 2022

Inspection Result: PASSED

Permit Number: PRMH220218

Issuance Date: Mar 10, 2022

Property Address: 60880 COUNTY ROAD 129, UNITA, ROUTT, CO 80428;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: MOUNTAIN HIGH MECHANICAL 10521 W 106th PI WESTMINSTER, CO 80021 (970) 846-5622

To construct: Make up air unit for kitchen. Unit heater for storage area. New hood for pizza oven with make up air and grease duct.

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All mechanical work for this permit is complete. Final Ansul report submitted. Final approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347