



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 09, 2022

Inspection Result: NOT READY

Permit Number: PRSL220302

Issuance Date: Apr 25, 2022

Property Address: 42375 RIVER DRUM TRL, ROUTT, CO 80487;

Applicant: Colorado Energy Systems LLC

Contractor: Colorado Energy Systems LLC 274 Mountain Shadow Drive Glenwood
Springs, CO 81601 (970) 456-4601

To construct: Furnish and Install 20 kw PV system
Ground mount system shown on site plan.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Good tie not compliant will need to be changed to supply side tap labeling will need to be in place documentation showing array rack system listed as Bond

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339