



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 20, 2022

Inspection Result: NOT READY

Permit Number: PREL221314

Issuance Date: Sep 19, 2022

Property Address: 18195 STATE HIGHWAY 131, ROUTT, CO 80483;

Applicant: Elizabeth Herbert

Contractor:

To construct: Permit needed to run electric to a wired cabin so that electric can be turned on.
Possible trench to be dug for electric line.

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Exposed wiring and incomplete circuits must be corrected prior to energizing service recall and corrected

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339