



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 22, 2022

Inspection Result: PASSED

Permit Number: PRPL220508

Issuance Date: May 11, 2022

Property Address: 21498 MOUNTAIN TOP DR, ROUTT, CO 80467;

Applicant: IQ PLUMBING & HEATING

Contractor: IQ PLUMBING & HEATING 895 RANNEY ST CRAIG, CO 81625 (970) 629-5125

To construct: Finish plumbing to bathrooms at Stagecoach Lodge. Men's room, women's room, mechanical room and kitchen upstairs.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Water and DWV, holding 100 and 5 psi

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371