



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 28, 2022

Inspection Result: PARTIAL PASS

Permit Number: PRMH221353

Issuance Date: Sep 20, 2022

Property Address: 21498 MOUNTAIN TOP DR, ROUTT, CO 80467;

Applicant: IQ PLUMBING & HEATING

Contractor: IQ PLUMBING & HEATING 895 RANNEY ST CRAIG, CO 81625 (970) 629-5125

To construct: Install a snowmelt system in concrete pad to be poured on north side of the building. This will consist of a boiler, tubing, exterior gas line and a fire pit fireplace.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Heat tube inspection of exterior walkways and patio. One loop, holding 105 psi

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371