



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 30, 2022

Inspection Result: PASSED

Permit Number: PRSL221268

Issuance Date: Sep 28, 2022

Property Address: 21498 MOUNTAIN TOP DR, ROUTT, CO 80467;

Applicant: Sunwise Solar and Efficiency, LLC

Contractor: Sunwise Solar and Efficiency, LLC PO Box 883137 Steamboat Springs, CO 80477 (970) 819-0840

To construct: Application to install off-grid power system at building using; ground-mounted solar array (12-modules, single pole), and inverter/battery power system. Not connected to utility. Feeding loads of Stagecoach Lodge building with standalone power system.

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Rebar cage per plan, 36" bore, 9 1/2' deep. Ready to pour

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371