



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 18, 2022

Inspection Result: PASSED

Permit Number: PRGS221522

Issuance Date: Oct 11, 2022

Property Address: 30535 MARSHALL RIDGE, ROUTT, CO 80487;

Applicant: SCHRADER PROPANE LLC

Contractor: SCHRADER PROPANE LLC P.O. BOX 775450 STEAMBOAT SPGS, CO
80477 (970) 819-7363

To construct: TANK SET & UNDERGROUND EXTERIOR GAS LINE INSTALLATION

On this day we have inspected your construction for **Gas Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 1 Underground propane tank set appropriate distance from house. Gas line installed in trench of proper depth in conduit and with trace wire. Gas line test is good at 22psi. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331