



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 18, 2022

Inspection Result: PASSED

Permit Number: PRAB221072

Issuance Date: Sep 16, 2022

Property Address: 27315 HOME RANCH RD, UNITJ, ROUTT, CO 80428;

Applicant: SNAKE RIVER CONSTRUCTION

Contractor: SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO 80477 (970) 846-2301

To construct: A new pavilion and bell tower structure will be constructed on the Home Ranch property which will be used to host a variety of events throughout the year. The pavilion will be constructed with wood purlins bearing on timber trusses which are supported by concrete spread footers. The bell tower will consist of a concrete masonry unit shaft supporting a timber framed roof above.

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Walls and piers have been formed correctly to most recent plans. All rebar is sized and spaced correctly. Approved to pour.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347