



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Oct 27, 2022

**Inspection Result:** PASSED

**Permit Number:** PRGS221616

**Issuance Date:** Oct 26, 2022

**Property Address:** 42375 RIVER DRUM TRL, UNITB, ROUTT, CO 80487;

**Applicant:** SCHRADER PROPANE LLC

**Contractor:** SCHRADER PROPANE LLC P.O. BOX 775450 STEAMBOAT SPGS, CO  
80477 (970) 819-7363

**To construct:** UNDERGROUND, EXTERIOR GAS LINE INSTALLATION

On this day we have inspected your construction for **Gas Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** New tank and gas line have been installed and bedded correctly. Pressure test good at 25 psi for 15 minutes. Approved to backfill.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347