



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Oct 31, 2022

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRPL221628

**Issuance Date:** Oct 30, 2022

**Property Address:** 29563 COUNTY ROAD 14D, ROUTT, CO 80487;

**Applicant:** ELLSWORTH PLUMBING & SERVICE

**Contractor:** ELLSWORTH PLUMBING & SERVICE P.O. BOX 772238 Steamboat  
Springs, CO 80477 (970) 457-0813

**To construct:** All plumbing for new modular home.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** In slab DWV, complete and holding 5 psi.

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371