



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Nov 17, 2022

**Inspection Result:** PASSED

**Permit Number:** PRGS221713

**Issuance Date:** Nov 17, 2022

**Property Address:** 21498 MOUNTAIN TOP DR, ROUTT, CO 80467;

**Applicant:** FERRELLGAS

**Contractor:** FERRELLGAS P.O. BOX 773360 STEAMBOAT SPGS, CO 80477 (970)  
879-1375

**To construct:** Underground propane tank install.

On this day we have inspected your construction for **Gas Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Gas line from tank installed, holding 19 psi. Ok to backfill

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371