



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Nov 22, 2022

Inspection Result: PARTIAL PASS

Permit Number: PREL210606

Issuance Date: Nov 15, 2021

Property Address: 27225 COUNTY ROAD 14, ROUTT, CO 80467;

Applicant: RIDGELINE ELECTRIC LLC

Contractor: RIDGELINE ELECTRIC LLC PO BOX 882442 STEAMBOAT SPRINGS,, CO
80488 (508) 769-6854

To construct: New Home. 4000 SF

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Steam generator circuit inadequately sized and no means of disconnect at equipment. All receptacles outside of dwelling require GFI protection including RV receptacle. Incomplete electrical work at subpanel East Side house at grade. Air conditioning circuit in garage panel but no visible air conditioning equipment. Hot tub circuit in garage panel no signs of connected hot tub.

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339