



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Nov 28, 2022

Inspection Result: PASSED

Permit Number: PRAB220245

Issuance Date: Oct 25, 2022

Property Address:

Applicant: SNAKE RIVER CONSTRUCTION

Contractor: SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO
80477 (970) 846-2301

To construct: A new bathroom building will be construction from regular stud walls with log siding siting on a traditional concrete foundation.

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 2 inches of closed cell foam installed in walls with R-13 batts over top. Lid has 18 plus inches of blown in fiberglass. foundation has 10 inch poly iso insulation around foundation. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331