



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jan 05, 2023

Inspection Result: PASSED

Permit Number: PREL221802

Issuance Date: Jan 03, 2023

Property Address: 12793 COUNTY ROAD 51B, ROUTT, CO 81639;

Applicant: BEHRMAN ELECTRIC LLC

Contractor: BEHRMAN ELECTRIC LLC 2038 WOODLAND AVE CRAIG , CO 81625
(970) 756-6801

To construct: Install 400 amp 3ph 480V CT Can, 4 200 amp Disconnects, 1 Meter can.

On this day we have inspected your construction for **Electrical Temp Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Underground approved

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339