



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School

# Corrections Notice

Permit Application Number: PRSP221690

January 05, 2023

Dear Applicant,

Following are the comments regarding the plan review for the below referenced application. We have noted several concerns and/or non-conforming items regarding the work to be performed. These items must be addressed through revised drawings and/or addendums submitted to the CityView Portal for us to complete our review and approval, thank you.

**Property Address:** 38625 ROLLINGHILLS LN, SFR, ROUTT, CO 80487

**Parcel No:** 937174003;

**Application Type:** On-Site Wastewater

**Type of** Not Applicable

**Construction:**

**Occupancy:**

**Environmental Health Review** (Reviewed By: Scott Cowman)

**Comments:** Septic permit will be issued retroactively once the following information is received and the permit fee is paid. Applicant needs to submit any available information regarding the connections from the secondary unit and the storage buildings. Information may include materials used, depths of pipes, bedding material, location of cleanouts, inspections reports, and photos. Application needs to verify in writing that line from storage buildings was capped and will no longer be used. All documents and information must be uploaded to this application and also relevant building permit applications.

If I can provide any further information to you, please feel free to contact me at 970-870-5401 or by email at scowman@co.routt.co.us

Thank you,  
Amanda Williams  
Environmental Health