



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jan 23, 2023

Inspection Result: PASSED

Permit Number: PRPL220828

Issuance Date: Jun 27, 2022

Property Address: 30535 MARSHALL RIDGE, ROUTT, CO 80487;

Applicant: CROSS MOUNTAIN PLMB & HEAT

Contractor: CROSS MOUNTAIN PLMB & HEAT P.O. BOX 771905 STEAMBOAT SPGS,,
CO 80477 (970) 819-4276

To construct: New construction DWV, water piping, gas piping and fixture set.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Water lines and DWV rough complete, nail plates and valves installed, water at 60 psi, DWV at 7psi

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371