



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Feb 21, 2023

Inspection Result: PASSED

Permit Number: PRMH221117

Issuance Date: Aug 12, 2022

Property Address: 30535 MARSHALL RIDGE, ROUTT, CO 80487;

Applicant: JDW INC

Contractor: JDW INC P.O. BOX 770562 STEAMBOAT SPGS, CO 80477 (970) 879-0642

To construct: AC, EXHAUST FANS, VENTING, ERV, DRYER VENT, MAU

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Dryer vent, exhaust fans, ERV and MAU/AC systems installed, duct work sealed and insulated. Condensor holding 500 psi

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371