



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Mar 03, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRSF220187

Issuance Date: Apr 20, 2022

Property Address: 30535 MARSHALL RIDGE, ROUTT, CO 80487;

Applicant: AMARON-FOLKESTAD CONSTRUCTION

Contractor: AMARON-FOLKESTAD CONSTRUCTION P.O. BOX 773103 STEAMBOAT
SPGS, CO 80477 (970) 879-9598

To construct: Single Family Home 5 Bedrooms 5 Baths

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Completion of rough framing, interior walls, per plan. Load points followed, steel connections welded/bolted, hangers/clips as called out.

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371