



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Mar 06, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRAU220370

Issuance Date: Jul 19, 2022

Property Address: 42375 RIVER DRUM TRL, UNITB, ROUTT, CO 80487;

Applicant: Altitude Custom Builders

Contractor: Altitude Custom Builders P O Box 883013, 970-238-0630 Steamboat Springs, CO 80488 (970) 238-0630

To construct: The New Construction of a Secondary Dwelling Unit.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Exterior sheathing has been installed and fastened correctly. Approved to cover.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347