



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Mar 21, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRMH230137

Issuance Date: Mar 03, 2023

Property Address: 27270 COUNTY ROAD 14, ROUTT, CO 80467;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: MOUNTAIN HIGH MECHANICAL 10521 W 106th PI WESTMINSTER, CO 80021

To construct: Installing heat tubing and warm-board. Connecting to existing boiler system.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Hydronic tubing, staple up and warm board, all through manifolds, two gauges both holding 100 psi.. OK for flooring

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371