



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Apr 12, 2023

Inspection Result: NOT READY

Permit Number: PRPL221734

Issuance Date: Nov 22, 2022

Property Address: 27315 HOME RANCH RD, UNITA, ROUTT, CO 80428;

Applicant: ACTION MECHANICAL INC.

Contractor: ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174

To construct: plbg for 1/2 bath

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments:

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347