



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Apr 12, 2023

Inspection Result: PARTIAL PASS

Permit Number: B-20-799

Issuance Date: Apr 20, 2021

Property Address: 27315 HOME RANCH RD, ROUTT, CO 80428;

Applicant: Paul Stoll

Contractor: SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO
80477 (970) 846-2301

To construct: Work Description: Garage, Kitchen & Mud Room addition for Columbine Cabin

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: See corrections, all other final building and life safety items are complete. Partial approved.

Corrections:

- 1 1. Install new layer of poly vapor barrier in mud room and kitchen crawl space.
2. Install propane gas detector in mechanical room in basement

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347