



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Apr 12, 2023

Inspection Result: PARTIAL PASS

Permit Number: M-20-707

Issuance Date: Nov 16, 2020

Property Address: 27315 HOME RANCH RD, ROUTT, CO 80428;

Applicant: Robert Serafin

Contractor: ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174
ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174

To construct: Work Description: heat tubing in garage

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: See correction, all other mechanical work is complete. Partial approved.

Corrections:

- 1 Install propane gas detector in basement mechanical room

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347