



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Apr 12, 2023

Inspection Result: PASSED

Permit Number: P-21-217

Issuance Date: Apr 26, 2021

Property Address: 27315 HOME RANCH RD, ROUTT, CO 80428;

Applicant: Robert Serafin

Contractor: ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174

To construct: Work Description: kitchen sink, laundry, bathroom

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All fixtures are operable, caulked and leak free. Final approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347