



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Apr 17, 2023

Inspection Result: PASSED

Permit Number: PRPL210543

Issuance Date: Nov 03, 2021

Property Address: 58000 COWBOY WAY, UNITB, ROUTT, CO 80428;

Applicant: MOUNTAIN HIGH MECHANICAL

Contractor: MOUNTAIN HIGH MECHANICAL 10521 W 106th PI WESTMINSTER, CO 80021

To construct: Floor drains for walk in coolers.

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All plumbing work for this permit is complete. Final approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347