



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: May 04, 2023

Inspection Result: NOT READY

Permit Number: PREL230360

Issuance Date: May 03, 2023

Property Address: 58000 COWBOY WAY, UNITB, ROUTT, CO 80428;

Applicant: JCH ELECTRIC LLC

Contractor: JCH ELECTRIC LLC P.O. BOX 881262 STEAMBOAT SPGS, CO 80488
(970) 819-1895

To construct: New electrical wiring in dining area

On this day we have inspected your construction for **Electrical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Sheetrock installed prior to electrical inspection all electrical work must be visible recall when sheetrock removed

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339