



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: May 05, 2023

Inspection Result: PASSED

Permit Number: PRPF221773

Issuance Date: Mar 16, 2023

Property Address: 28305 YELLOW JACKET DR, ROUTT, CO 80467;

Applicant: Stephen Jones

Contractor:

To construct: Factory built 572 sq ft home on 20 acre parcel

On this day we have inspected your construction for **Foundation Drain Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Perforated PVC, wrapped, gravel bedded, cleanouts installed, OK to cover.

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371