



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: May 22, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRAU221615

Issuance Date: May 01, 2023

Property Address: 29860 COUNTY ROAD 14, ROUTT, CO 80487;

Applicant: Jeremy Grasser

Contractor: JDG CONSTRUCTION P O BOX 770550 STEAMBOAT SPRINGS, CO
80477-0550 (970) 819-0566

To construct: This building was permitted as an AG Barn in 2020 under B-20-940, this permit is to create a SDU within the existing building.
Grade beam under bearing walls
Steel moment frames around windows and doors
Complete living quarters

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Grade beam under slab, four #4, hooped 18" oc, pads per plan, ok to pour.

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371