



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** May 23, 2023

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRSF220716

**Issuance Date:** Nov 01, 2022

**Property Address:** 38625 ROLLINGHILLS LN, SFR, ROUTT, CO 80487;

**Applicant:** Leslie H Christensen

**Contractor:**

**To construct:** This is a new permit application for a home already built and has an expired building permit without final inspections

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Final electrical approved for TCO. Receptacle near laundry room sink will need GFI protection. Romex cord cap combination for rope light will have to be UL listed assembly. Chandelier over bathtub will have to be removed. Water heater wiring will have to be corrected. Damaged weatherproof covers around exterior of dwelling will have to be replaced. On-site meeting with electrical contractor making repairs will be necessary to address additional concerns

**Corrections:**

Sincerely,

Tom Cook  
Electrical Plan Reviewer/Inspector  
tcook@co.routt.co.us  
(970) 870-5339