

Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

## **INSPECTION REPORT**

Report Issued: May 24, 2023 Inspection Result: PASSED

Permit Number: PRRF230409 Issuance Date: May 23, 2023

Property Address: 38955 MUD ALY, ROUTT, CO 80487;

Applicant: Ski Town Roofing, LLC

Contractor: Ski Town Roofing, LLC 29445 Scrub Oak Path Steamboat Springs, CO

80487 (970) 457-7088

To construct: Removing 20SQ's of 26ga pro panel, replacing with new 26ga pro panel, full

ice and water shield, and flashings.

On this day we have inspected your construction for **Roofing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Roof fully dried in with all new Roofnado underlayment, flashing and boots. Approved to install metal panels.

## **Corrections:**

Sincerely,

Silas Ebbert Inspector sebbert@co.routt.co.us (970) 870-5347