



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: May 24, 2023

Inspection Result: PASSED

Permit Number: TB-21-934

Issuance Date: Sep 17, 2021

Property Address: 50310 MOON HILL DR, ROUTT, CO 80487;

Applicant: Nathan NicholasNathan Nicholas

Contractor: Mr. Gumpox Industries P O Box 773434 Steamboat Springs, Co 80477
(970) 819-6740

To construct: 1,797 square foot single family home with detached garage.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All final building and life safety items are complete. Final approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347