



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: May 26, 2023

Inspection Result: PASSED

Permit Number: PRPL221658

Issuance Date: Nov 02, 2022

Property Address: 42375 RIVER DRUM TRL, UNITB, ROUTT, CO 80487;

Applicant: COLORADO PLUMBING & HEATING

Contractor: Colorado Plumbing Inc P O BOX 273438 Fort Collins, CO 80524 (970) 484-9923

To construct: New Plumbing System

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All DWV, water and gas lines are installed, supported and protected correctly. Pressure tests good for 15 minutes. Rough plumbing approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347