



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** May 26, 2023

**Inspection Result:** PASSED

**Permit Number:** PRMH221659

**Issuance Date:** Nov 02, 2022

**Property Address:** 42375 RIVER DRUM TRL, UNITB, ROUTT, CO 80487;

**Applicant:** COLORADO PLUMBING & HEATING

**Contractor:** COLORADO PLUMBING & HEATING P.O. BOX 775302 STEAMBOAT  
SPGS, CO 80477 (970) 846-6478

**To construct:** Radiant Heat System with Boiler and Gas Piping.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Gas lines are installed, supported and protected correctly. Pressure test good at 15 psi for 15 minutes.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347