

Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued:	May 31, 2023	Inspection Result:	PARTIAL PASS
•	•	·	
Permit Number:	PRSF221403		
Issuance Date:	Apr 10, 2023		
Property Address:	26730 COUNTY ROAD 14, ROUTT, CO 80467;		
Applicant:	SUSTAINABLE BUILDING SOLUTIONS		
Contractor:	SUSTAINABLE BUILDING SOLUTIONS P.O. BOX 770578 STEAMBOAT		
	SPGS,, CO 80477 (970) 819-4311		
To construct:	New Single Family Home With Attached Garage at 26730 County Road 14.		

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Cages for piers, four verticals, tied with #3 hoops 12"oc with three at the top. Per plan

Corrections:

Sincerely,

Jeff Yeiser Inspector jyeiser@co.routt.co.us (970) 870-5371