



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Jun 07, 2023

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRAU220370

**Issuance Date:** Jul 19, 2022

**Property Address:** 42375 RIVER DRUM TRL, UNITB, ROUTT, CO 80487;

**Applicant:** Altitude Custom Builders

**Contractor:** Altitude Custom Builders P O Box 883013, 970-238-0630 Steamboat Springs, CO 80488 (970) 238-0630

**To construct:** The New Construction of a Secondary Dwelling Unit.

On this day we have inspected your construction for **Drywall Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** 1st layer of 5/8" X installed correctly on garage ceiling. Approved to install 2nd layer.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347