



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jun 09, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRAB221337

Issuance Date: Jun 07, 2023

Property Address: 38625 ROLLINGHILLS LN, SFR, ROUTT, CO 80487;

Applicant: Leslie H Christensen

Contractor:

To construct: Construction of 3 storage buildings

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Call for final again when spray foam covered in storage buildings. Water to bathhouse has been disconnected and toilets removed and cemented closed. Partial approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347