



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jun 22, 2023

Inspection Result: PARTIAL PASS

Permit Number: PREL230646

Issuance Date: Jun 20, 2023

Property Address: 28305 YELLOW JACKET DR, ROUTT, CO 80467;

Applicant: STAGECOACH ELECTRIC, INC.

Contractor: STAGECOACH ELECTRIC, INC. P.O. BOX 775508 STEAMBOAT
SPRINGS, CO 80477 (970) 846-3316

To construct: Electrical Service for modular home installation.

On this day we have inspected your construction for **Electrical Perm Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Permanent service to modular dwelling conditionally approved. Feeder to structure requires an equipment ground Bond jumper will need to be removed at dwelling and ground wires will have to be separated from neutral bus at dwelling prior to closing out permit

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339