



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jun 23, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRPL230674

Issuance Date: Jun 22, 2023

Property Address: 34130 WHIFFLE TREE TRL, ROUTT, CO 80467;

Applicant: ELLSWORTH PLUMBING & SERVICE

Contractor: ELLSWORTH PLUMBING & SERVICE P.O. BOX 772238 Steamboat Springs, CO 80477 (970) 457-0813

To construct: All plumbing for new build

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: In slab water and DWV complete, DWV holding 7 psi and water 60 psi.

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371