



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jul 05, 2023

Inspection Result: FAILED

Permit Number: PREL230480

Issuance Date: May 26, 2023

Property Address: 42375 RIVER DRUM TRL, UNITB, ROUTT, CO 80487;

Applicant: COONS CUSTOM ELECTRIC INC.

Contractor: COONS CUSTOM ELECTRIC INC. P.O. BOX 882379 STEAMBOAT SPGS,,
CO 80488 (970) 846-5609

To construct: Electrical for Secondary Dwelling Unit

On this day we have inspected your construction for **Electrical Temp Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Service riser incomplete. Bond jumper to bond bushing on nipple between meter socket and service disconnect not installed. No grounding electrode connected

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339