



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Jul 05, 2023

**Inspection Result:** PASSED

**Permit Number:** PRSF220411

**Issuance Date:** Jul 25, 2022

**Property Address:** 34130 WHIFFLE TREE TRL, ROUTT, CO 80467;

**Applicant:** Christopher S Reed

**Contractor:**

**To construct:** new single family build on slab.

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** In slab heat tube, on R-10 dimple foam, holding 80 psi

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371