



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jul 05, 2023

Inspection Result: PASSED

Permit Number: PRRF230687

Issuance Date: Jun 30, 2023

Property Address: 29775 DRY CREEK TRL, ROUTT, CO 80467;

Applicant: Ski Town Roofing, LLC

Contractor: Ski Town Roofing, LLC 29445 Scrub Oak Path Steamboat Springs, CO 80487 (970) 457-7088

To construct: Removing 33.12SQ's of laminated shingles. Installing Malarkey Windsor Shingles on main roof and standing seam metal on the eyebrows and dog house vents. Full ice and water shield and new flashings.

On this day we have inspected your construction for **Roofing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All pitches Roofnado Ice and Water membrane. Ok for shingles.

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371