



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jul 13, 2023

Inspection Result: PASSED

Permit Number: PREL230749

Issuance Date: Jul 10, 2023

Property Address: 25850 ZSUZSIYAMA LN, ROUTT, CO 80428;

Applicant: DJ Anderson

Contractor: <NO STREET ADDRESS>

To construct: YVEA needs inspection of existing meters to turn on electric after 40 years.

On this day we have inspected your construction for **Electrical Perm Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Permanent electrical service approved for reconnection house meter number 54780 and well meter number 54766. Existing meters seals in place no approval sticker attached

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339