



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Jul 14, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRAD221473

Issuance Date: Nov 30, 2022

Property Address: 27315 HOME RANCH RD, UNITA, ROUTT, CO 80428;

Applicant: SNAKE RIVER CONSTRUCTION

Contractor: SNAKE RIVER CONSTRUCTION PO BOX 773504 Steamboat Springs, CO
80477 (970) 846-2301

To construct: Construction of the 'Fitness Building' portion of the Lodge

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Foundation wall for breezeway and fitness pavilion Formed to size on approved plans. All rebar installed is sized and spaced correctly. Required void forms in place. Approved to close walls and pour when ready

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331